

DECEMBER 2021 NATURALLY OCCURRING ASBESTOS (NOA)

Clear < 0.016 Str/cc

Exceedance
≥ 0.016 Str/cc

	Location 2 Downwind: Connecticut St Interior Perimeter	Location 3 Crosswind: 25th St Side Interior Perimeter	Location 1 Upwind: Wisconsin St Interior Perimeter
Date	str/cc	str/cc	str/cc
12/1/21	<0.00050	<0.00090	<0.00090
12/2/21	0.0010	0.0046	0.00050
12/3/21	<0.00090	<0.0010	<0.0010
12/6/21	<0.00090	0.0018	<0.00090
12/7/21	0.0018	<0.00090	<0.00090
12/8/21	<0.00090	<0.00090	<0.00090
12/9/21	<0.00090	<0.00090	<0.00090
12/10/21	<0.00090	<0.00090	<0.00090
12/13/21			
12/14/21	<0.0010	<0.0010	<0.0010

	Location 2 Downwind: Connecticut St Interior Perimeter	Location 3 Crosswind: 25th St Side Interior Perimeter	Location 1 Upwind: Wisconsin St Interior Perimeter
Date	str/cc	str/cc	str/cc
12/15/21	<0.00090	<0.0010	<0.0010
12/16/21	<0.0010	<0.00090	<0.00090
12/17/21	0.0028	<0.0010	<0.00090
12/20/21	0.0010	0.0019	0.00090
12/21/21	0.0074	<0.0010	0.0010
12/22/21			
12/23/21			
12/24/21			
12/27/21			
12/28/21	0.0027	0.0018	<0.00090
12/29/21			
12/30/21	0.00090	0.00090	<0.00090
12/31/21	<0.00090	0.013	<0.00090

Note: Rainouts witnessed - 12/13, 12/22, 12/23, and 12/27 – No construction occurred onsite.
12/24 – Holiday – No construction occurred onsite.