

June 19 – June 23, 2023
Weekly Air Monitor Report
Potrero Phase 2
Infrastructure

WEEKLY AIR MONITORING RESULTS

BRIDGE Monitors for the Following:

Naturally Occurring Asbestos (NOA)
Particulates or PM10

Note: Any detection above the project action level is investigated and mitigation measures proposed.

6/19/23 – 6/23/23: NOA WEEKLY REPORT

Clear < 0.016 s/cc
Exceedance ≥ 0.016 s/cc

	Location 1 Upwind: Wisconsin St Perimeter	Location 2 Downwind: Connecticut St Perimeter	Location 3 Crosswind: 25th St Perimeter
Date	s/cc	s/cc	s/cc
6/19/23	<0.0009	0.0180	0.0019
6/20/23	<0.0009	0.0120	<0.0009
6/21/23	0.0009	0.0036	<0.0009
6/22/23	<0.0009	0.0085	0.0038
6/23/23	<0.0009	0.0036	0.0018

NOA reports
posted @

<http://www.rebuildpotrero.com/airmonitoring>

6/19/23 – 6/23/23: NOA RESPONSE ACTIONS AND WEEKLY DATA SUMMARY

Date(s): One reading above the action level for the week starting 6/19/23; June 19, downwind monitor, 0.0180 s/cc.

Potential Source: Excavation and soil stockpiling adjacent to the downwind monitor.

Response Action: In order to address this reading on the 19th, the contractor will be adding additional water to the stockpile to ensure adequate moisture is maintained and ensuring the exit installed uphill from the monitor is maintained throughout the day.

Weekly Data Summary: All other readings were below the action level.

6/19/23 – 6/23/23: PM10 WEEKLY REPORT

Dust Monitoring Report
Potrero Phase 2
6/19/23 - 6/23/23

監測結果
波特雷羅第二階段
6/19/23至6/23/23

*Informe de monitoreo de
polvo
Potrero Fase 2*

Clear $\leq 0.05 \text{ mg/m}^3$

安全

No supera los límites

Exceedance $> 0.05 \text{ mg/m}^3$

超出標準

Supera los límites

Date	Daily (24 Hr) Average in mg/m^3		
	Monitor 1 (Upwind)	Monitor 2 (Downwind)	Monitor 3 (Crosswind)
6/19/23	0.003	0.003	0.005
6/20/23	0.004	0.003	0.005
6/21/23	0.007	0.006	0.009
6/22/23	0.007	0.008	0.006
6/23/23	0.005	0.005	0.005

Note: Dust Monitoring reports posted 粉塵報告公佈於 @

Los informes del polvo se publican en <http://www.rebuildpotrero.com/airmonitoring>